



Filta-Wash Pty Ltd – “The original & the best”

Buy online from our [eBay Store](#) or simply contact us with your order.

 (07) 4951 4611  onlinesales@filtawash.com.au



Cartridge Replacement Times

7 Stage R/O System

As a general rule, any cartridges **BEFORE** the membrane, should be replaced every 6 months.

The membrane itself will last between 3-5 years.

The post carbon GAC (taste and odour cartridge) should be replaced every 12 months.

The Mineral Stone and/or Far Infra Red Cartridges every 2 years.

The magnetic Water treatment device will not need replacing.

So, on a standard 7 stage system the changes would be similar to this:

Poly Spun Sediment Cartridge – 6 months

Carbon Block Cartridge – 6 months

Membrane – 3/5 years

Mineral Stone Cartridge – 2 years

Far Infra Red Cartridge – 2 years

Post GAC (taste/odour) Cartridge - 12 months

Magnetic Water Treatment System – never